

# Memorandum

---

**To: Alan Auld, PURCHASING OFFICER – STORES**

---

**From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES**

---

**cc:**

---

**Date:** 08 June 2004

---

**Re: Purchase Specification – Brass Gate Valves, Brass Globe Valves & Brass Non-Return Valves.**

---

**File Reference:** pm:kb 50/001/0028

---

## **BRASS GATE VALVES, BRASS GLOBE VALVES & BRASS NON-RETURN VALVES**

### **PURCHASE SPECIFICATION.**

- 1.0 Brass gate valves, brass globe valves and brass non-return valves are to be in accordance with Australian Standard AS 1628 - Water Supply – Metallic Gate, Globe and Non-Return Valves.
- 2.0 Class 14 pressure rating (min. working 1200 kPa), generally below-ground conditions.
- 3.0 All copper alloy components are to be Dezincification-Resistant (DR).
- 4.0 Gate valves to be clockwise closing.
- 5.0 Non-return valves to be 'swing' type.
- 6.0 Product certification in accordance with AS 1628.
- 7.0 Purchaser to specify nominal size and end connection arrangement.

Prepared by  
Phil McKone  
**STRATEGIC ASSETS AND COMPLIANCE ENGINEER.**

Endorsed by  
Dan Toon  
**EXECUTIVE MANAGER COMMERCIAL SERVICES.**