

Memorandum

To: Alan Auld, PURCHASING OFFICER – STORES

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 30 September 2004

Re: Purchase Specification – Single Detector Check Valve.

File Reference: pm:kb 50/001/0028

SINGLE DETECTOR CHECK VALVE.

PURCHASE SPECIFICATION.

- 1.0 Valve size will be nominated at time of purchase.
- 2.0 Class 14 pressure rating (min. working 1200 kPa), generally above-ground conditions.
- 3.0 No bypass required.
- 4.0 End connections to double flanged.
- 5.0 Flanges to be AS2129 Table 'C' or 'E'.

Prepared by
Phil McKone RPEQ
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon RPEQ
EXECUTIVE MANAGER COMMERCIAL SERVICES.