

# Memorandum

---

**To: Alan Auld, PURCHASING OFFICER – STORES**

---

**From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES**

---

**cc:**

---

**Date:** 20 October 2004

---

**Re: Purchase Specification – Sewerage Vent Pole.**

---

**File Reference:** pm:kb 50/001/0028

---

## **SEWERAGE VENT POLE.**

### **PURCHASE SPECIFICATION.**

- 1.0 Sewerage vent poles are to be used at all sewage pump stations and sewage discharge manholes.
- 2.0 Hot dipped galvanised mild steel round tapered pole type.
- 3.0 Terrain Category 2, Wind Region C.
- 4.0 6m length, 1 piece (no sections).
- 5.0 Base plate mounted.
- 6.0 100mm ID at pole top.
- 7.0 Complete with access door.
- 8.0 Complete with galvanised foundation reinforcing cage and bolts.

Prepared by  
Phil McKone RPEQ  
**STRATEGIC ASSETS AND COMPLIANCE ENGINEER.**

Endorsed by  
Dan Toon RPEQ  
**EXECUTIVE MANAGER COMMERCIAL SERVICES.**