

Memorandum

To: Alan Auld, PURCHASING OFFICER – STORES

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 30 September 2004

Re: Purchase Specification – Polyethylene Sleeving for Ductile Iron Pipes.

File Reference: pm:kb 50/001/0028

POLYETHYLENE SLEEVING FOR DUCTILE IRON PIPES.

PURCHASE SPECIFICATION.

- 1.0 Polyethylene sleeving for ductile iron (DICT) pipes is to be in accordance with Australian Standard AS 3680 - Polyethylene Sleeving for Ductile Iron Pipe.
- 2.0 Installation of the sleeving will be in accordance with AS 3681.
- 3.0 Size of the sleeving will be specified at time of purchase and be designated by the applicable pipe nominal size.
- 4.0 Colour of the sleeving will be specified at time of purchase and be designated by the applicable pipe use being:

water supply	-blue
raw sewage	-cream
treated effluent recycling	-lilac
- 5.0 No perforations.
- 6.0 Product certification in accordance with AS 3680.

Prepared by
Phil McKone
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon
EXECUTIVE MANAGER COMMERCIAL SERVICES.