

Memorandum

To: Alan Auld, PURCHASING OFFICER – STORES

From: Dan Toon, EXECUTIVE MANAGER – COMMERCIAL SERVICES

cc:

Date: 08 June 2004

Re: Purchase Specification – Stainless Steel Globe Valves.

File Reference: pm:kb 50/001/0028

STAINLESS STEEL GLOBE VALVES

PURCHASE SPECIFICATION.

- 1.0 Stainless Steel globe valves are to be in accordance with Australian Standard AS 1628 - Water Supply – Metallic Gate, Globe and Non-Return Valves.
- 2.0 Class 14 pressure rating (min. working 1200 kPa), generally below-ground conditions.
- 3.0 Product certification in accordance with AS 1628.
- 4.0 Purchaser to specify nominal size and end connection arrangement.

Prepared by
Phil McKone
STRATEGIC ASSETS AND COMPLIANCE ENGINEER.

Endorsed by
Dan Toon
EXECUTIVE MANAGER COMMERCIAL SERVICES.